

---

**From:** Marquis, Luke  
**Sent:** Monday, July 28, 2014 12:25 PM  
**To:** TSF Inspector  
**Cc:** Ostritchenko, Dmitri  
**Subject:** RE: Daily Report - July 27, 2014

Hello Davis

We have been getting some higher values back in the most recent proctors and I have noticed that your compaction values are going up as well so going forward can you please use a max density of 2100 kg/m<sup>3</sup> instead of 2055 kg/m<sup>3</sup>. Thanks,

Luke Marquis E.I.T  
Geotechnical Engineer  
AMEC Environment & Infrastructure  
3456 Opie Crescent  
Prince George, BC V2N 2P9  
Ph:250-564-3243 Cell: 250-640-3244 Fax:250-562-7045  
[luke.marquis@amec.com](mailto:luke.marquis@amec.com)  
[amec.com](http://amec.com)

---

**From:** TSF Inspector [<mailto:tsfinspector@mountpolley.com>]  
**Sent:** July-27-14 4:58 PM  
**To:** Ostritchenko, Dmitri; Marquis, Luke  
**Cc:** Nicholas Bergeron  
**Subject:** Daily Report - July 27, 2014